

LP Gas Cylinder Checklist

Stall Holder Name:

LP Gas Safety must be completed by stallholders using LPG including barbeques.		Yes	No	Action if No
Appliances Your stall holder site is an extension of your workplace. Stall holders must ensure: <ul style="list-style-type: none"> • documented procedures for various tasks associated with the use of LP Gas are in place • all personnel carrying out these tasks are adequately trained • records are kept to demonstrate personnel have received instructions in the specific method 	Only certified appliances in use			
	Service history available			
	In good condition			
	Safety devices not tampered with			
	Taps & knobs in good condition and marked			
	Not on a combustible surface			
	In well vented location			
	Clearances from LP Gas cylinder			
	External appliances not in an internal location			
	Appliance pressure does not exceed 3 kPa			
	Hoses for appliance are acceptable			
Regulators & Hoses	Regulators in good condition			
	Regulator hose of approved material			
	Hoses in good condition			
Cylinders	Protected from accidental damage			
	Hoses less than 3m in length			
	Cylinder within 10-year test date			
	Cylinder in good condition			
	Cylinder connection checked for leaks			
Located away from flammable materials and ignition source				
Cylinder not blocking exit or path of travel				

Please provide contact details included name and mobile of representative on site

Name:	Mobile:
-------	---------

This statement indicates that I/we the stall holder have implemented the following control measures for our site and activities during the event (event name)

Person Responsible:	Signature:
Position:	Date: